

	<p style="text-align: center;">Florida Department of Health Charlotte County Environmental Engineering</p>	<p style="text-align: center;">1100 Loveland Blvd Port Charlotte, FL 33980 941-624-7200 http://charlotte.floridahealth.gov/</p>
--	--	---

Fact Sheet for Limited Use Water Systems (LUPWS)

Operating Permit (Rule 64E-8.004, FAC):

The annual Operating Permit LUPWS expires each year on September 30th and must be renewed each year by October 1st. The Operating Permit Application Form DH4092A must be completed with any changes and submitted to the Department of Health along with the application fee and forms. The Department will issue the Operating Permit if the application is complete, all fees have been paid, and the LUPWS complies with Chapter 64E-8, FAC. **Operating Permits are nontransferable.**

Annual Inspections, Operation, and Maintenance (Rule 64E-8.005, FAC):

Every permitted LUPWS must be inspected at least once every 12 months. Every LUPWS may be inspected at any time as Quality Assurance in response to complaints, or for any reason as required by the Department. All equipment on the LUPWS shall function properly and be kept in good condition at all times. The minimum pressure is 20 psi. If the water system is shut down for any reason, including as a result of loss of power due to hurricanes or any other natural disaster, the Department must be notified within 24 hours of such shut down. Bacteriological samples will need to be collected, tested and determined to be free from contamination before the water system can be cleared for resumption of potable water consumption

Bacteriological Requirements (Rule 64E-8.006(3)(6), FAC):

Every calendar quarter, at a minimum there must be a satisfactory microbiological analysis of a sample of finished water taken from a remote location on the distribution system. If the LUPWS includes disinfection (chlorination), a source (well) water sample for microbiological analysis must also be taken on the same day.

- First quarter (October, November, December): Suggest sample in October
- Second quarter (January, February, March): Suggest sample in January
- Third quarter (April, May, June): Suggest sample in April
- Fourth quarter (July, August, September): Suggest sample in July

All system owners shall report laboratory analysis results to the Department within five (5) days of receipt. (64E-8.006(5)) The required sampling may be done by the owner, operator, a water service, or by the Department. Call (239) 274-2000 for information on having sampling conducted by the Department. All water samples must be analyzed by a NELAC certified laboratory.

If a bacteriological water sample is positive for coliform bacteria, per Rule 64E-8.007, FAC, a second water sample should be taken within 24 hours and submitted to the laboratory. If the second sample is positive, corrective action must be taken, including but not limited to disinfection of the



Florida Department of Health
Charlotte County
Environmental Engineering

1100 Loveland Blvd
Port Charlotte, FL 33980
941-624-7200
<http://charlotte.floridahealth.gov/>

LUPWS. In order to allow enough time for any resampling and/or corrective actions, the required bacteriological sampling must be completed as soon as possible during the calendar quarter.

Lead and Nitrate Requirements (Rule 64E-8.006(3)(a), FAC):

Every LUPWS must be sampled for lead and nitrate per Chapter 64E-8, FAC, as follows:

- Commercial LUPWS must be sampled every five (5) years
- Community LUPWS must be sampled every three (3) years.

Chlorinated Systems (Rule 64E-8.005(1)(d), FAC):

Disinfection equipment (chlorinated systems) shall maintain a free available chlorine residual 0.2 mg/L and a maximum of 4.0 mg/L residual throughout the entire LUPWS. Where continuous disinfection is required, the supplier shall test the chlorine residual **daily** by using a N,N-Diethyl-p-Phenyldiamine (DPD) color comparison test kit, or a portable spectrophotometer test kit and post the results in a log kept on premises. Where continuous disinfection is required for a LUPWS and a chemical disinfectant is used, the supplier shall assure a state certified water treatment plant operator services the system weekly and record the services in the log. Monthly, Monthly Operating Reports, (MOR's) should be sent to the Department within 10 days after the end of the month during which the evaluation was completed.

Registered Limited Use System (Rule 64E-8.004(5), FAC):

Some commercial LUPWS may be exempt from obtaining an annual operating permit if that water system does not make tap water available for public consumption. Suppliers of registered systems must perform annual testing for bacteria in the form of one (1) satisfactory microbiological sample per year. The analysis shall be performed no more than twelve (12) months apart and the results shall be provided to the Department no later than fifteen (15) days after time period in which the sample was required. **Re-registration is required upon change of system ownership.**

Call our office if you have any questions ~~(914) 624-7200~~.
(941-624-7200)